



- ## NORTH LOOP



SECONDARY CONDUIT AND CABLE SCHEDULE			
TO	DESCRIPTION	REMARK	
MD8 10			
MDP6	2 - 4 #350 MCM & 1 #2/OG -4" C		
MDP7	2 - 4 #350 MCM & 1 #2/OG -4" C		
MDP24	2 - 4 #4/0 MCM & 1 #1/OG -4" C		
MDP22			
MSB 19	5 - 4 #500 MCM & 1 #4/OG -4" C		
XFMR T99-480			
MDP23			
MDP106	2 - 4 #4/0 MCM & 1 #1/OG -4" C		
MSB18	5 - 4 #500 MCM & 1 #4/OG -4" C		
MD136			
MDP			
MSB2	4 - 4 #350 MCM & 1 #4/OG -4" C		ETR
MDP2A	2 - 4 #4/0 MCM & 1 #1/OG -4" C		ETR
MSB17	5 - 4 #500 MCM & 1 #4/OG -4" C		
MSB18	10 - 4 #600 MCM - 4" C		ETR
MSB1A	2 - 4 #600 MCM - 4" C		ETR
DPNH1	2 - 4 #600 MCM - 4" C		ETR
MSB104	8 - 4 #500 MCM - 4" C		ETR
MDP3	3 #1/0 & 1 #6G - 2" C.		
MDP4	3 #4/0 & 1 #2G - 4" C.		ETR
MD27	3 #1 & 1 #6G - 2" C.		
DISC SW.			
MD99-480			

VA FORM 08-6231